

# DVGW type examination certificate


## DVGW-Baumusterprüfzertifikat

**DG-8531BR0270**

Registration Number  
Registriernummer

<b>Field of Application</b> <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
<b>Owner of Certificate</b> <i>Zertifikatinhaber</i>	COMAP Industries 46, rue de l'Industrie, F-45550 Saint-Denis de l'Hotel
<b>Distributor</b> <i>Vertreiber</i>	COMAP S.A. 16, avenue Paul Santy, F-69000 Lyon Cedex 08
<b>Product Category</b> <i>Produktart</i>	installation systems and system joints: Compression joint for metallic gas pipes (8531)
<b>Product Description</b> <i>Produktbezeichnung</i>	Compression joint made of copper and red brass for copper pipes according to GW 392, optional leaky in the non-pressed state according to DVGW-VP 614, chapter 4.4.1 (LBP)
<b>Model</b> <i>Modell</i>	SudoPress Visu Control (LBP)
<b>Test Reports</b> <i>Prüfberichte</i>	laboratory control test: 120001141-11 from 02.05.2011 (MPM)
<b>Test Basis</b> <i>Prüfgrundlagen</i>	DVGW VP 614 (01.05.2005)

**Date of Expiry / File No.** 10.05.2015 / 12-0529-GNV  
*Ablaufdatum / Aktenzeichen*

31.08.2012 Rie A-1/2   
Date, Issued by, Sheet, Head of Certification Body  
*Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle*

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-01

DVGW CERT GmbH  
Josef-Wirmer-Straße 1-3  
53123 Bonn

Telefon: +49 228 91 88-888  
Telefax: +49 228 91 88-993  
eMail: info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
SudoPress Visu Control (LBP)	nominal pressure rating: PN 5/GT 1 nominal diameter: DN 12	
SudoPress Visu Control (LBP)	nominal pressure rating: PN 5/GT 1 nominal diameter: DN 15	
SudoPress Visu Control (LBP)	nominal pressure rating: PN 5/GT 1 nominal diameter: DN 18	
SudoPress Visu Control (LBP)	nominal pressure rating: PN 5/GT 1 nominal diameter: DN 22	
SudoPress Visu Control (LBP)	nominal pressure rating: PN 5/GT 1 nominal diameter: DN 28	
SudoPress Visu Control (LBP)	nominal pressure rating: PN 5/GT 1 nominal diameter: DN 35	
SudoPress Visu Control (LBP)	nominal pressure rating: PN 5/GT 1 nominal diameter: DN 42	
SudoPress Visu Control (LBP)	nominal pressure rating: PN 5/GT 1 nominal diameter: DN 54	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
VCG 5001	bow 90°
VCG 5002	bow 90° I/A
VCG 5040	bow 45°
VCG 5041	bow 45° I/A
VCG 5130	T-piece
VCG 5130 R	reduced T-piece
VCG 5243	reducing piece I/A
VCG 5270	sleeve
VCG 5275	sliding sleeve
VCG 5290	plug
VCG 5301	cap
VCG 4270 G	transition sleeve with internal thread
VCG 4280 G	plug in nipple with external thread
VCG 4281 G	plug in sleeve with internal thread
VCG 4471 G	ceiling-angle with 3 hole flange
VCG 4001 G	screwing in elbow 90° with external thread
VCG 4090 G	angle 90° with internal thread
VCG 4130 G	T-piece with internal thread
VCG 4243 G	transition nipple with external thread
SudoPress Visu Control LBP	leaky in the non-pressed state according to DVGW-VP 614, chapter 4.4.1

### certified Components

#### zertifizierte Bauteile / Werkstoffe

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5112BQ0329	Sealing material made of elastomers for TH5/03/1/TH5/03/1 gas appliances		Superior Seals Limited
DG-5112BS0407	Sealing material made of elastomers for 70HN120p/70HN120p gas appliances		BodeDynamic GmbH

### Hints of Utilization / Remarks

#### Verwendungshinweise / Bemerkungen

ambient temperature range: -20...+70 °C

The requirements of the higher thermal resistance are fulfilled until pressure rating PN 1 (GT 1).